
INFORMATION ONLY

CENTRAL MAINE POWER DG INTERCONNECTION COMMUNICATIONS SCHEME DIAGRAM (APPROVED CELLULAR SOLUTION + TARIFF RATE PARTICIPANTS ONLY) REV. 01-16-2024

"SITE NAME" "TOWN", MAINE



UNDERGROUND CONDUIT - Minimum 24" below ground level

LEGEND:

STP SHIELDED TWISTED PAIR CABLE SMF SINGLE-MODE FIBER CABLE POTS PLAIN OLD TELEPHONE SERVICE CES CARRIER ETHERNET SERVICE NID NETWORK INTERFACE DEVICE RTU REMOTE TERMINAL UNIT ECC ENERGY CONTROL CENTER GOAB GANG-OPERATED AIR BREAK (SWITCH) GND GROUND

NOTE

*** SCHEME DIAGRAM REPRESENTS A TYPICAL INSTALLATION. CMP IS NOT RESPONSIBLE FOR ENGINEERING OF DEVELOPER OR TELCO EQUIPMENT.